

December 20, 2004

WIESER CONCRETE PRODUCTS, INC.  
MARK WIESER  
2815 RILEY ROAD  
PORTAGE WI 53901

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)  
Manufacturer: WIESER CONCRETE PRODUCTS, INC.  
Product Name: BIO-MICROBICS MICROFAST 0.9 AND 1.5 AND HIGH STRENGTH FAST 1.0 AND 1.5  
Model Number(s): W2400 BIO  
Product File No: 20040603

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2009.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.
- A tank with a minimum capacity of 500 gallons must be located upstream of this product whenever two Bio-Microbics 0.9 Microfast units or 1.0 High Strength Fast units are installed in this product.
- This tank may only be used in conjunction with the Bio-Microbics Inc., Sing Home Fast 0.9 and 1.5 units and High Strength Fast 1.0 and 1.5 units.
- This product may have two MicroFAST 0.9 or two HighstrengthFAST 1.0 units installed in the tank.

This approval supersedes the approval issued on INSERT DATE under product file number 20000017.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20000017.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

WIESER CONCRETE PRODUCTS, INC.

Page 2

December 20, 2004

Sincerely,

Michael J. Beckwith, CIPE

Plumbing Product Reviewer

phone: 608-266-6742

fax: 608-267-9566

e-mail: [mike.beckwith@wisconsin.gov](mailto:mike.beckwith@wisconsin.gov)